



MCB 3P 6kA C-32A 3M

MU332A

#### Architecture

Neutral position	not applicable
Number of protected poles	3
Number of poles	3 P
Type of pole	3 P
Concurrently switching N-neutral	no
Fixing mode	Din-Rail
Curve	C

#### Controls and indicators

With fault indicator	no
----------------------	----

#### Main electrical features

Frequency	50/60 Hz
Rated short circuit breaking capacity $I_{cn}$ AC according IEC60898-1	6 kA
Type of supply voltage	AC
Rated operational voltage $U_e$	400 V

#### Voltage

Rated insulation voltage	500 V
Rated impulse withstand voltage	4000 V

#### Electric current

Rated short circuit breaking capacity $I_{cn}$ under 400V AC according IEC60898-1	6 kA
Rated service breaking capacity $I_{cs}$ AC according IEC 60898-1	6 kA
Breaking capacity on 1 pole with 400 V NF 60947-2	3 kA
Rated ultimate short-circuit breaking capacity $I_{cu}$ under 415V AC IEC 60947-2	10 kA
Magnetic regulating current at 40° C	5/10 $I_n$
min/maxi threshold value of the DC magnetic operation	7/15 $I_n$
min/maxi threshold value of the AC thermal operation	1,13/1,45 $I_n$
min/maxi threshold value of the DC thermal operation	1,13/1,45 $I_n$

#### Electric current / temperature

Rating current -15°C	39,3 A
Rating current -20°C	40,1 A
Rating current 0°C	37,1 A
Rating current 10°C	35,5 A
Rating current -10°C	38,6 A
Rating current 15°C	34,6 A
Rating current 20°C	33,8 A
Rating current 25°C	32,9 A
Rating current -25°C	40,8 A
Rating current 30°C	32 A
Rating current 35°C	31,1 A
Rating current 40°C	30,1 A
Rating current 45°C	29,1 A
Rating current 5°C	36,3 A
Rating current -5°C	37,8 A
Rating current 50°C	28,1 A
Rating current 55°C	27,1 A
Rating current 60°C	26 A
Rating current 65°C	25 A
Rating current 70°C	24 A

#### Current correction factors

Correction factor of magnetic tripping with 100 Hz	1,1
Correction factor of magnetic tripping with 200 Hz	1,2
Correction factor of magnetic tripping with 400 Hz	1,5
Correction factor of magnetic tripping with 60 Hz	1
Correction factor of rating current for 2 devices placed 1 side-by-side	
Correction factor of rating current for 3 devices placed 0,95 side-by-side	
Correction factor of rating current for 4 and 5 devices placed side-by-side	0,9
Correction factor of rating current for 6 devices placed 0,85 side-by-side	

#### Power

Power loss per pole at I <sub>n</sub>	4,67 W
Total power loss under I <sub>N</sub>	12,3 W

#### Endurance

Electric endurance in number of cycles	4000
Number of mechanical operations	20000

#### Dimensions

Depth of installed product	70 mm
Height of installed product	83 mm
Width of installed product	52,5 mm

#### Installation, mounting

Tightening torque	2,8Nm
-------------------	-------

#### Connection

type of connection	with screw
Top and bottom screw terminals connection capacity with flexible cable	1/16 mm <sup>2</sup>
Top and bottom screw terminals connection capacity with rigid cable	1/25 mm <sup>2</sup>

#### Equipment

Can be accessorized	no
Quick connect	no

#### Standards

Standard text	IEC 60898-1
European directive RoHs	voluntary compliance
European directive WEEE	concerned

#### Safety

Protection index IP	IP20
---------------------	------

#### Use conditions

Degree of pollution according to IEC 60664 / IEC 60947-2	2
Class of energy limitation I <sup>2</sup> t	3
Altitude	2000 m
Storage temperature	-25 to 80 °C
Air humidity protection	for all climates